STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 80415
Permit No.
Basin 79

NOTICE OF INTENT NO 44667

1. OWNER **David Keever** ADDRESS AT WELL LOCATION **16300 Fetlock**
MAILING ADDRESS **1700 Whitewood Dr**
Sparks NV

2. Location **NW** 1/4 **NW** 1/4 Sec **3** T **23N** R **18E** **Washoe** County
PERMIT NO. PARCEL N0. **078-231-05** SUBDIVISION NAME

3. WORK PERFORMED
X New Well | Replace | Recondition
Deepen | Abandon | Other

4. PROPOSED USE
X Domestic | Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. W ELL TYPE
Cable | X Rotary | RVC
Air | Other | X Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay & boulders.		**0**	**85**	**85**
				0
Broken rock.		**85**	**145**	**60**
				0
Brown clay & sands.		**145**	**178**	**33**
				0
Brown clay.		**178**	**230**	**52**
				0
Multi colored sand.		**230**	**272**	**42**
				0
Gray clay.		**272**	**548**	**276**
				0
Broken granite.		**548**	**565**	**17**
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

Date started **5-24** -2000
Date completed **6-2** -2000

7. WELL TEST DATA
TEST METHOD: Bailer Pump x Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
10	25	
20	**150**	
30	300	

8. WELL CONSTRUCTION
Depth Drilled **565** feet Depth Cased **565** feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	inches	**0**	feet	**100**	feet
8 3/4	inches	**100**	feet	**300**	feet
6 1/8	inches	**300**	feet	**565**	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
6 5/8	**12.94**	**188**	**+1 1/2**	**300**
5	**696**	**188**	**285**	**565**

Perforations::
Type Perforation **Factory**
Size perforation **3/32 x 3"**
From **260** feet to **280** feet
From **545** feet to **565** feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal **X** YES No
Depth of Seal **50** feet
Pumped
x Poured
Gravel Packed: **X** Yes No
From **50** feet to **300** feet

Seal Type:
Neat Cement
Cement Grout
X Concrete Grout

9 WATER LEVEL
Static water leve **150** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**
Signed
By driller performing actual drilling on site or contractor
Date 6-6 -2000