WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80459
Permit No.
Basin 48

NOTICE OF INTENT NO. 3756

1. OWNER **JOHN & DONNA MARR**
MAILING ADDRESS **2822 LANDAU CT.**
HENDERSON, NV 89014

ADDRESS AT WELL LOCATION **NE CORNER OF PICKERING & 17TH**

2. LOCATION **NW** 1/4 **SW** 1/4 Sec. **17** T **32N** N/S R **55E** E **ELKO** County
PERMIT NO. (Issued by Water Resources) **028-016-005** (Parcel No.) **LUCKY NUGGET #2** (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	3	3
SILTSTONE		3	80	77
RED ROCK		80	360	280
GRAY ROCK	420	360	460	100

RECEIVED 00 APR 22 PM 3:06 STATE ENGINEER'S OFFICE

Date started **04/17/2000**, 19__
Date completed **04/19/2000**, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		6

8. WELL CONSTRUCTION
Depth Drilled **460** Feet Depth Cased **460** Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	460	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	460

Perforations:
Type perforation **MILLSLOT**
Size perforation **3/16 X 3**
From **440** feet to **460** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal **50**
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From **50** feet to **460** feet

9. WATER LEVEL
Static water level **390** feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature **C** °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **HACKWORTH DRILLING, INC** (Contractor)
Address **P.O.BOX 850** (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board **020582**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**
Signed (by driller performing actual drilling on-site or contractor)
Date **04/25/2000**

USE ADDITIONAL SHEETS IF NECESSARY