WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80460
Permit No.
Basin 48

NOTICE OF INTENT NO. 37568

1. OWNER FREHNER CONSTRUCTION
MAILING ADDRESS HC 34 BOX 10
ELKO, NV 89801

ADDRESS AT WELL LOCATION OFF HWY 228 AT TWIN BRIDGES TURN OFF

2. LOCATION SW 1/4 NW 1/4 Sec. 30 T 32N N/S R 56E E ELKO County
PERMIT NO. WAIVER C-199 (Issued by Water Resources) BLM (Parcel No.) TRACT OF LAND (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic Road contr. [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
SILTSTONE & GRAVEL		2	200	198
BROWN SILTSTONE		200	380	180
BROWN VOLCANICS	430	380	460	80

Date started 05/09/2000 , 19__
Date completed 05/10/2000 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+		4

8. **WELL CONSTRUCTION**
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	460 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	460

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 420 feet to 460 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 460 feet

9. **WATER LEVEL**
Static water level 280 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 05/11/2000

USE ADDITIONAL SHEETS IF NECESSARY