WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80461
Permit No.
Basin

NOTICE OF INTENT NO. [redacted]

1. OWNER JEROME HOMES
MAILING ADDRESS 366 SPRING CREEK PARKWAY
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION
AURORA DRIVE AND JACKSON AVE.

2. LOCATION SE 1/4 SW 1/4 Sec. 5 T 35N N/S R 57E E ELKO County
PERMIT NO. (Issued by Water Resources) | 026027008 (Parcel No.) | TWIN RIVER RANCHES #4 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	3	3
SAND & GRAVEL		3	12	9
CEMENT & GRAVEL	X	12	72	60
GRAY SANDSTONE		72	158	86
LOOSE SAND & GRAVEL	X	158	172	14

Date started 6/8/00, 19__
Date completed 6/11/00, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		2.5hr.

8. WELL CONSTRUCTION

Depth Drilled 172 Feet Depth Cased 172 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	172 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	188	+1.5	172

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 151 feet to 172 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55 FT
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 172 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Company (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6-14-00