WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80464
Permit No.
Basin 177

NOTICE OF INTENT NO. 44080

1. OWNER ERNEST EGAN
MAILING ADDRESS HC 60, BOX 204
WELLS, NV 44080

ADDRESS AT WELL LOCATION
OFF HIGHWAY 93, CLOVER VALLEY WELLS, NV

2. LOCATION SW 1/4 NW 1/4 Sec. 27 T 35N N/S R 62 E ELKO County
PERMIT NO. (Issued by Water Resources) | 008320031 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	3	3
SAND		3	6	3
CLAY		6	34	28
HARD SANDSTONE		34	65	31
SAND & GRAVEL	X	65	68	3
CLAY		68	82	14
SAND & GRAVEL	X	82	110	28
CLAY		110	130	20
GRAVEL	X	130	140	10

Date started 5/22/00, 19__
Date completed 5/24/00, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300		3.5

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		250	+1	140

Perforations:
Type perforation MILL SLOT
Size perforation 1/4" X 4"
From 70 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 140 feet

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Company (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6-6-00