WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Mo-2000-1

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80477
Permit No.
Basin 137B

NOTICE OF INTENT NO. 44762

1. OWNER Round Mountain Gold Corporation
MAILING ADDRESS P.O. Box 480
Round Mountain Nevada 89045
ADDRESS AT WELL LOCATION Round Mountain Gold Corporation Pit

2. LOCATION NW ¼ NE ¼ Sec. 30 T. 10 N/S R. 44 E. Nye County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tuff		0	320'	320
Granite		320'	505'	185'
Neat Cement		0	10'	10'
⅜ Hole Plug		10'	67'	57'
Sand Pack		67	495'6"	428'6"

Date started 6-20 2000
Date completed 6-22 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
105'	10		5 min.
205'	10		5 min.
305	20		5 min
405	30		5 min.
505	30		5 min

8. WELL CONSTRUCTION
Depth Drilled 505 Feet Depth Cased 495'6" Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14" Inches		0 Feet	10' Feet
7.5 Inches		10 Feet	505' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10⅝"		⅜ wall	0	10'
3"		SCH 40	+1	495'6"

Perforations:
Type perforation Horz Slot
Size perforation 0.020
From 417'2" feet to 476'8" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 67' feet to 495'6" feet

9. WATER LEVEL
Static water level 1'4" feet ~~below~~ above land surface
Artesian flow 9 G.P.M. 5 P.S.I.
Water temperature 105 °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co. (Contractor)
Address P.O. Box 2748 (Contractor)
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1786
Signed Craig Dines
By driller performing actual drilling on site or contractor
Date 6-22-2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627