WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80482
Permit No.
Basin 103

NOTICE OF INTENT NO. 41953

1. OWNER Don Keith
MAILING ADDRESS Lucie DR. CC Carson City NV. 89701
ADDRESS AT WELL LOCATION 102 Merrill Ct. Dayton NV.

2. LOCATION NE ¼ NE ¼ Sec. 12 T. 16 N/S R. 21 E. Lyon County
PERMIT NO. (Issued by Water Resources) 19-654-03 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Overburden | | 0 | 3 | 3 |
| Course DG Sands | | 3 | 29 | 26 |
| Hard Pan | | | | |
| Brown Clay | | 29 | 63 | 34 |
| Line DG Sands | | 63 | 144 | 81 |
| W Clay Stratas | | | | |
| | XX | 144 | 180 | 36 |
| Course Volcanic | | | | |
| Fractured Rock | | | | |
| Course Gravels | | | | |

RECEIVED 00 AUG -3 AM 10:18 STATE ENGINEERS OFFICE

Date started 7-23, 1900
Date completed 7-24, 1900

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | 30 | 3 HRS |

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
10 3/4 Inches From 0 Feet To 180 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | 0 | 180 |

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Warm °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR. (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 7-30-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627