

OFFICE USE ONLY
Log No. 80484
Permit No. _____
Basin 103

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41999

1. OWNER Kath & Janet Willis
MAILING ADDRESS 3196 Parkview Dr. Carson City NV 89701
ADDRESS AT WELL LOCATION 1444 Parkview Dr. Carson City NV 89701
2. LOCATION NE 1/4 NE 1/4 Sec. 23 T. 15 N/S R. 20 E. CARSON County
PERMIT NO. 010-086-08 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DB Sands</u>		<u>0</u>	<u>63</u>	<u>63</u>
<u>Coarse Volcanic Sands</u>		<u>63</u>	<u>90</u>	<u>37</u>
<u>Very Fine Sands Brown</u>		<u>90</u>	<u>96</u>	<u>6</u>
<u>Volcanic Sands and Small Clay Strata</u>		<u>96</u>	<u>110</u>	<u>14</u>
<u>Large River Gravels and Volcanic Sands DB Sands</u>	<u>XX</u>	<u>110</u>	<u>145</u>	<u>35</u>

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet
HOLE DIAMETER (BIT SIZE)
From 10 3/4 Inches To 0 Feet 145 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>145</u>

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 125 feet to 145 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 100 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 100 feet to 145 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow _____ G.P.M. 25 ft P.S.I.
Water temperature 110 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat Dr. Carson City NV 89706 Contractor
Nevada contractor's license number issued by the State Contractor's Board 41795
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1905
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 8-2-00

Date started 8-1 1900
Date completed 8-2 1900

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25 ft</u>	<u>2.5</u>	<u>3 hrs</u>