WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80485
Permit No.
Basin 89

NOTICE OF INTENT NO. 34836A

1. OWNER George Gillemot
MAILING ADDRESS P.O. Box 370
Glenbrook, NV 89413

ADDRESS AT WELL LOCATION 4814 Old 395 N. Carson

2. LOCATION SE 1/4 SW 1/4 Sec. 3 T 16N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 055-042-19 Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [X] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we attempted to reduce the amount of sand that the well was delivering. We installed a 4.5" ID PVC well casing (flush thread) to bottom. We installed 4 cu ft of #3 sand around the annulus between the 4.5" and the 6" steel casing. We then developed the well and the result was to reduce the amount of sand by 98%. There were still some fines coming into the sand filters, but will probably get less and less as time goes on.				

Date started 5/5/2000, 19__
Date completed 5/6/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	20	72 Hrs

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 PVC		Sch 40	5	145

Perforations:
Type perforation Factory
Size perforation .030 slot
From 100' feet to 140' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 13 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed P. Bruce MacKay (by driller performing actual drilling on-site or contractor)
Date 5/23/00

USE ADDITIONAL SHEETS IF NECESSARY