WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80504
Permit No. 29614
Basin 212

NOTICE OF INTENT NO. 18930

1. OWNER Atlandia Design
MAILING ADDRESS 3260 Industrial Road
Las Vegas, NV 89109

ADDRESS AT WELL LOCATION #3

2. LOCATION NE ¼ SE ¼ Sec. 20 T 21 N/S R 61 E Clark County
PERMIT NO. 29614/R 1038 (Issued by Water Resources) | 162-20-501-002 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~Originally drilled to 1396', currently filled in to 810'~~				
~~Pumped 336 sacks of Aqua Guard grout thru 2" tremmie pipe from 810' to 60'~~				
~~Pumped 6 yards of sand slurry (8sack) thru 2" tremmie pipe from 60' to surface~~				

AUG 14 2000

Date started July 26, 2000, 19
Date completed July 29, 2000, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
xx 12"		blank	325	450

Perforations:
Type perforation Existing
Size perforation
From 50 feet to 325 feet
From 450 feet to 810 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. Existing WATER LEVEL
Static water level 80 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co., Inc. (Contractor)
Address 7227 Hauck Street (Contractor)
Las Vegas, NV 89118

Nevada contractor's license number 4286A
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2120

Signed Richard Thompson
By driller performing actual drilling on site or contractor

Date August 10, 2000

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627