WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80595
Permit No.
Basin 162

NOTICE OF INTENT NO. 20366

1. OWNER Ron Murphy
MAILING ADDRESS 4260 W. Maple
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
4260 W. Maple

2. LOCATION SW 1/4 NE 1/4 Sec. 23 T 20S N/S R 52E E Nye County
PERMIT NO. Issued by Water Resources
41-443-24 Parcel No.
Golden Springs Ranch Subdivision Name

3. WORK PERFORMED
X New Well Replace Recondition
Deepen Abandon Other

4. PROPOSED USE
X Domestic Irrigation Test
Municipal/Industrial Monitor Stock

5. WELL TYPE
Cable X Rotary RVC
Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	3	3
grey clay		3	38	35
brown loam		38	40	2
light green loam	x	40	68	28
grey loam	x	68	107	39
See next line	x	107	115	8
grey loam and caleche strings				
brown loam	x	115	132	17
light green clay	x	132	140	8

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation sawcut
Size perforation .188
From 125 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: X Yes No
Depth of Seal 50
Placement Method: Pumped
X Poured

Seal Type:
Neat Cement
Cement Grout
X Concrete Grout

Gravel Packed: X Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor

Address 2301 Winery Road, Suite 2
Contractor

Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Larry Strickland
By driller performing actual drilling on-site or contractor

Date 6-19-00

CONFIDENTIAL
AUG 3 2000

Date started 6/17/00 19__
Date completed 6/17/00 19__

7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)