



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32364

1. OWNER Warren Coverstone ADDRESS AT WELL LOCATION Lot #4 Northeast end of Jason Lane
 MAILING ADDRESS HC 65 Box 17
Auston, NV 89310

2. LOCATION SW 1/4 NW 1/4 Sec. 9 T. 35 N/S R. 35 E Esmeralda County
 PERMIT NO. 007-351-19 White Mtn Estates Subdivision Name

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
3/4 gravel & Br clay	NO	0	23	23
6" rock; no clay	NO	23	26	3
3/8" gravel; no clay	NO	26	56	30
Gravel; some clay	NO	56	76	20
6" rock; & rocks	NO	76	78	2
Brn clay; sand;				
1/2" sm gravel	Yes	78	127	49
6" + rocks	Yes	127	130	3
Brn clay	Yes	130	140	10
Rock hard granite	Yes	140	141	1
Clay & rock	Yes	141	152	11
Loose 3/8" gravel; clay	Yes	152	175	23
Cemented brn clay				
some gravel	Yes	175	230	55
Gravel tight/no clay	Yes	230	263	33

8. WELL CONSTRUCTION
 Depth Drilled 263 Feet Depth Cased 258 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 258 Feet
9 7/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.305 (SDR21)	0	258

Perforations:
 Type perforation Saw cut
 Size perforation 3" x 1 1/16
 From 150 feet to 250 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50' feet to 258 feet

9. WATER LEVEL
 Static water level 126 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality Good

Date started 4/5/2000, 19____
 Date completed 4/11/2000, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	200	} 2 Hrs
50	225	
60	250	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maranatha Drilling & Pump Service Contractor
 Address 22893 Hwy 6 Contractor
Benton, CA 93512

Nevada contractor's license number 039576
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1238
 Division of Water Resources, the on-site driller

Signed Russell Kels
 By driller performing actual drilling on site or contractor

Date 7-12-00