WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80681
Permit No.
Basin 162

NOTICE OF INTENT NO. 19089

1. OWNER Moffat
MAILING ADDRESS 3471 W. Mesquite Ave. Pahrump, Nevada 89048
ADDRESS AT WELL LOCATION 3471 W. Mesquite Ave. Pahrump, Nevada 89048

2. LOCATION NW ¼ NE ¼ Sec. 1 T. 20 N OR 52 E Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 41-551-11 Subdivision Name Golden Spring Ranch Unit 5

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	10'	10'
caliche		10'	15'	5'
white clay		15'	30'	15'
caliche ~~brown clay~~		30'	35'	5'
brown clay		35'	70'	35'
caliche		70'	75'	5'
white clay		75'	90'	15'
brown clay		90'	120'	30'
caliche		120'	125'	5'
brown clay		125'	140'	15'

AUG 17 2000

Date started July 11, 2000
Date completed July 18, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.625	4.33	.316	0	140

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Co. (Contractor)
Address 4191 S. Jackie St. (Contractor)
Pahrump, Nevada 89048
Nevada contractor's license number issued by the State Contractor's Board 049225
Nevada driller's license number issued by the Division of Water Resources, the onsite driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date Aug. 9, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627