WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80692
Permit No.
Basin 212

NOTICE OF INTENT NO. 17234

1. OWNER Paul Taylor c/o Conoco Inc
MAILING ADDRESS 600 N Dairy Ashford
P.O. Box 2197 Houston, TX 77252

ADDRESS AT WELL LOCATION 3901 Ponderosa Way
Las Vegas, Nev 89118

2. LOCATION SE ¼ NE ¼ Sec. 31 T. 21 N/S R. 61 E. Clark County

PERMIT NO. ____ Issued by Water Resources | Parcel No. 16231605001 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sandy Clay		0	3.0	3'
Caliche		3.0	13.0	10'
Sandy Clay		13.0	28	15'
Caliche		28.0	42.0	14'
Sandy Gravel (Hard)		42	67	25'
Caliche		67	68	1.0'
Sandy Clay		68	95	27.0'

AUG 2 2000

Date started 6-27 2000
Date completed 6-27 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 95 Feet Depth Cased 95 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	95 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2		1/4	0	95

Perforations:
Type perforation Factory Slotted
Size perforation .020
From 70 feet to 95 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 95 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MCCS
Contractor
Address 1930 Village Center Circle Ste 3-382
Contractor
Las Vegas, Nev 89130

Nevada contractor's license number issued by the State Contractor's Board 47851

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057

Signed [signature]
By driller performing actual drilling on site or contractor

Date 7-14-2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627