



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17234

1. OWNER Paul Jay Lee c/o Conoco Inc ADDRESS AT WELL LOCATION 3921 Ponderosa Way  
P.O. Box 2197 Rhyolite, NV 89118 Las Vegas, Nev 89118  
 2. LOCATION SE 1/4 NE 1/4 Sec. 31 T. 21 N. R. 61 E. Clark County  
 PERMIT NO. 16231605001 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other None

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SANDY CLAY GRAVEL</u>		<u>0</u>	<u>16'</u>	<u>16'</u>
<u>CAULIC</u>		<u>16'</u>	<u>18'</u>	<u>2'</u>
<u>SANDY CLAY</u>		<u>18'</u>	<u>30'</u>	<u>12'</u>
<u>CAULIC</u>		<u>30'</u>	<u>67'</u>	<u>37'</u>
<u>SANDY CLAY</u>	<u>74</u>	<u>67</u>	<u>95'</u>	<u>23'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 95 Feet Depth Cased 95 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 0 Feet 95 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 1/2</u>		<u>1/4</u>	<u>0</u>	<u>95</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 0.75  
 From 70 feet to 95 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to 95 feet

9. WATER LEVEL  
 Static water level 74 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MCCS Contractor  
 Address 1930 Village Center Circle Ste 3-382  
Las Vegas, Nev 89130 Contractor

Date started 7-26 DDO  
 Date completed 7-26 DDO

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Nevada contractor's license number issued by the State Contractor's Board 47851  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-14-2000