(4 wells) wdc

WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80695
Permit No.
Basin 212

NOTICE OF INTENT NO. 17234

1. OWNER Paul Taylor c/o Conoco Inc
MAILING ADDRESS 600 N Dairy Ashford P.O. Box 2197 Houston Tex 77252
ADDRESS AT WELL LOCATION 3901 Ponderosa Way Las Vegas 89118

2. LOCATION SE ¼ NE ¼ Sec. 31 T. 21 N/S R 61 E CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. 16231605001 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	4"	4"
Subgrade Type 2		4"	1.0'	8"
Silty Sandy Gravel		1.0'	16'	15'
Caliche		16'	30'	14'
Sandy Clay		30'	33'	3'
Caliche		33'	50	22'
Sandy Clay/Gravels		50	70'	20'
Caliche		70'	72'	2'
Sandy Clay	74	72'	100	28'

Date started 6-25 2000
Date completed 6-28 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	100 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2		1/4	0	100

Perforations:
Type perforation Factory Slotted
Size perforation .020
From 70 feet to 70 feet
From 90 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 100 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MCCS Contractor
Address 1930 Village Center Circle Ste 3-382 Contractor
Las Vegas, Nev 89130
Nevada contractor's license number issued by the State Contractor's Board 47887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2087
Signed By driller performing actual drilling on site or contractor
Date 9-14-2000

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627