

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. **80755**
Permit No. **215**
Basin **215**
Date **2/14/98**

1. OWNER Green Results ADDRESS AT WELL LOCATION 3500 S. D. Street Reno NV 89500
MAILING ADDRESS Green Results P.O. Box 1000 Reno NV 89500

2. LOCATION 1/4 Sec 19 T19N R6E S8E COUNTY Washoe
PERMIT NO. 240-366019 Parcel No. 190-366019 Subdivision Name Parcels

3. WORK PERFORMED
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	2	
SANDS		2	14	
SANDS / GLETT		15	37	

8. WELL CONSTRUCTION
 Depth Drilled: 50 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches: 11 Inches
 From _____ To _____
 Inches: _____ Feet
 From _____ To _____
 Feet: _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>3/16"</u>	<u>0</u>	<u>0</u>

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Stock Test Cable Rotary RVC Air Other _____

5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC Air Other _____

Perforations:
 Type perforation: POC
 Size perforation: 200
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal: 15
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 18 feet to 50 feet

9. WATER LEVEL
 Static water level: 37 feet below land surface
 Artesian flow: _____ G.P.M. _____ P.S.I.
 Water temperature: _____ °F Quality: _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the reports title to the best of my knowledge.
 Name THE DRILLER
 Address 2450 S. 16th Street Reno NV 89500
 Nevada contractor's license number 023-045899
 Issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller MT74774

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M. (Feet Below Static)			
Time (Hours)			

Date started: 8-4-88 1988
 Date completed: 8-1-88 1988
 Signed: _____
 Date: 8-10-88
 By driller performing actual drilling on site or contractor