WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80767
Permit No.
Basin 212

NOTICE OF INTENT NO. 20678

1. OWNER HOME DEPOT USA INC.
MAILING ADDRESS 3800 W. CHAPMAN AVE
ORANGE, CA 92868

ADDRESS AT WELL LOCATION 5991 S. PECOS RD
LAS VEGAS, NV

2. LOCATION SE ¼ NE ¼ Sec 36 T 21 N/S R 61 E CLARK County
PERMIT NO. R-1039 (Issued by Water Resources) Parcel No. 162-36-601-020 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon 2 wells				
#1 Perforate stopped at 65'				
on obstruction.				
Well depth 127'				
Perforated up to 49' and				
Filled with 3 1/4 yard 27 sac				
cement slurry via trimmie to				
well bottom.				
Static level at 14'				
#2 Perforation necessary due				
to hammering of drill pipe				
against casing.				
Filled with 2 yards 27 sac				
cement slurry via trimmie to				
well bottom. 111' Depth				
Static level at 14'				

Date started August 1 2000
Date completed August 2 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 111 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 14' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed (By driller performing actual drilling on site or contractor)
Date 8/22/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627