WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80832
Permit No.
Basin 212

NOTICE OF INTENT NO. 21921

1. OWNER LAS VEGAS PAVING
MAILING ADDRESS 4470 S. Decatur Las Vegas, NV 89103
ADDRESS AT WELL LOCATION End of Sunset Rd & Las Vegas Wash

2. LOCATION SW ½ S ½ Sec. 30 T. 21 N/S R. 63 E CLARK County
PERMIT NO. Dewater Issued by Water Resources | 160-30-003 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Dewatering
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other well point

6. LITHOLOGIC LOG 200 well points

Material	Water Strata	From	To	Thickness
Set up Boom Truck		0	20' Appx	
And pulled Appx 370				
well points - As per				
State of Nevada				
Division of Water				
Resources Requirement				
Pulled out and				
Holes caved in				
And Replaced well				
Points - Removed				
And surrounded mat.				
Consisted of River				
Sand & Gravel.				
Holes were 17' to				
20' Right in middle				
of River, water @				
4'				

Date started 7-24-00, 19
Date completed 7-28-00, 19

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 17'-20' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
2	0	20

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	well points	

Perforations:
Type perforation Factory Perf well points
Size perforation .020
From 20' feet to 18' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Abandonment			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foothill Eng & Dewatering Contractor
Address 905 E. Third St Contractor
Corona, Ca 91719
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119
Signed By driller performing actual drilling on site or contractor
Date 7-24-00

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627