WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80873
Permit No.
Basin 212

NOTICE OF INTENT NO. 21921

1. OWNER LAS VEGAS PAVING
MAILING ADDRESS 4420 S. Decatur Las Vegas, NV 89103
ADDRESS AT WELL LOCATION End of Sunset Rd & Las Vegas Wash

2. LOCATION SW ½ S ½ Sec. 30 T. 21 N/S R 63 E. CLARK County
PERMIT NO. DW1112 (Issued by Water Resources) 160-30-003 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Dewatering
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other well point

6. LITHOLOGIC LOG 200 well points

Material	Water Strata	From	To	Thickness
Set up Boom Truck And pulled Appx 300 well points - As per State of NEVADA Division of Water Resources Requirement		0	20' Appx	
Pulled out and Holes caved in And Replaced well Points - Removed And stripped. Mat. Consisted of River Sand & Gravel. Holes were 17' to 20' Right in middle of River, water @ 4'				

Date started 7-24-00, 19
Date completed 7-28-00, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Abandonment			

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 17'-20' Feet

HOLE DIAMETER (BIT SIZE)
2 Inches From 0 Feet To 20 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	well points	

Perforations:
Type perforation Factory Perf well points
Size perforation .020
From 20' feet to 18' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foothill Eng & Dewatering (Contractor)
Address 905 E. Third St (Contractor)
Corona, Ca 91719
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-24-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627