

OFFICE USE ONLY
 Log No. 80919
 Permit No. _____
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21221

1. OWNER CAS VEGAS PAUING ADDRESS AT WELL LOCATION East of Sunset Rd & CAS VEGAS WASH
 MAILING ADDRESS 4420 S. DeCatur Las Vegas, NV 89103
 2. LOCATION SW 1/4 S 1/4 Sec. 30 T. 21 N/S R. 63 E CLACK County
 PERMIT NO. DW 110 Parcel No. 160-30-003 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE De-watering
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other well point

6. 200 well points LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Set up Boring Truck		0	20	Appx
And pulled Appx 300 well points - AS PER STATE OF NEVADA Division of Water Resources Requirement				
Pulled out and Holes Cased in and Replaced well points - Removed and replaced Mat. Consisted of River Sand & Gravel. Holes were 17 to 20' Right in middle of River, water @ 4'				

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 17'20" Feet
 HOLE DIAMETER (BIT SIZE)
 From 2 Inches To 20 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>P.V.C.</u>	<u>Sch 40</u>	<u>Well points</u>	

Perforations:
 Type perforation Factory Perf well points
 Size perforation 0.20
 From 20 feet to 18' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Foothill Eng & Contractors Contractor
 Address 905 E. Third St Contractor
Corona, Ca 91717
 Nevada contractor's license number issued by the State Contractor's Board 0035906
 Nevada driller's license number issued by the Division of Water Resources, the on site driller M2119
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-24-00

Date started 7-24-00, 19_____
 Date completed 7-28-00, 19_____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
<u>Abandonment</u>			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	