

OFFICE USE ONLY  
 Log No. 81030  
 Permit No. \_\_\_\_\_  
 Basin 107  
 NOTICE OF INTENT NO. 44583

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Roy Carrasco ADDRESS AT WELL LOCATION 43 Old Ranch Rd. Smith Valley Washington  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION N.W. 1/4 S35 1/4 Sec. 12 T. 10 N/S R. 23 E. Lyon County \_\_\_\_\_  
 PERMIT NO. NA Issued by Water Resources Parcel No. 10-711-23 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other MPI

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		1	3	
Clay Sand		3	23	
Clay		23	34	
Gravel		34	68	
Clay Gravel		68	121	
Clay		121	130	
Gravel		130	153	
Clay		153	180	

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 1 3/8 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>17.5</u>	<u>1.88</u>	<u>1</u>	<u>180</u>

Perforations:  
 Type perforation Machine Perforated  
 Size perforation 3/16 x 10  
 From 140 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 60'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 180 feet

Date started 6/16/00, 19\_\_\_\_  
 Date completed 6/17/00, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80-90</u>	<u>4.5</u>	<u>4 hrs</u>

9. WATER LEVEL  
 Static water level 22' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jean Drilling Inc Contractor  
 Address PO Box 597 Contractor  
83 NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6/13/00