WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81032
Permit No.
Basin 107

NOTICE OF INTENT NO. 43073

1. OWNER Donald R Leverty Inc
MAILING ADDRESS P.O. Box 439
Genoa, Nv 89411

ADDRESS AT WELL LOCATION #20 Desert Creek Road

2. LOCATION SW ¼ NE ¼ Sec. 29 T. 10 N/S R. 24 E. Lyon County
PERMIT NO. _____ Issued by Water Resources | 10-761-06 Parcel No. | Desert Creek Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Unsorted Large Boulders		3	83	80
Gravel w/ Clay Seams		83	111	28
Boulders Cemented Gravel		111	250	139
Gravel Small Cobbles	✓	250	342	92
Boulders Cemented Gravel		342	457	115
Gravel & Pebbles	✓✓	457	520	63

Date started 6-1- 00
Date completed 6-23 00

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	20+		1½

8. WELL CONSTRUCTION
Depth Drilled 520 Feet Depth Cased 520 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	100 Feet
9 7/8 Inches	100 Feet	280 Feet
6 1/4 Inches	280 Feet	520 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	188	+2	280
4 1/2	PVC		+2	~~500~~ 520

Perforations:
Type perforation Saw Cut
Size perforation 1/8 x 5
From 240 feet to 260 feet
From 460 feet to 520 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 280 feet

9. WATER LEVEL
Static water level 295 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board: 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-29-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627