WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81036
Permit No.
Basin 107

NOTICE OF INTENT NO. 42047

1. OWNER West Ridge Homes Inc
MAILING ADDRESS 1187 A. High School St
Gardnerville, NV 89410
ADDRESS AT WELL LOCATION 546 upper Colony Rd
Wellington, NV

2. LOCATION NW ¼ SW ¼ Sec. 10 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 10-193-11 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine DG		0	97	97
DG with Br Clay		97	109	12
Med DG		109	182	73
DG with Br Clay		182	190	8
Med DG		190	205	15
Br Clay		205	227	22
Gray Sandy Clay	✓	227	272	45
Gray Sand with Clay Seams	✓	272	285	13

Date started 7-14 ,00
Date completed 7-20 ,00

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	+25		1hr

8. WELL CONSTRUCTION
Depth Drilled 285 Feet Depth Cased 285 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	100 Feet
9 7/8 Inches		100 Feet	285 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	13	.108	+2	285

Perforations:
Type perforation Factory Milled
Size perforation 1/8 x 3
From 265 feet to 285 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 285 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-24-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627