

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 81039  
 Permit No. 107  
 Basin                       
 NOTICE OF INTENT NO. 27328

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Kim Stewart ADDRESS AT WELL LOCATION 161 Day Lane  
 MAILING ADDRESS P.O. Box 234 Smith NV 89430 Log # 506  
Smith NV 89430 well # 27 State engineer map  
 2. LOCATION NE 1/4 NE 1/4 Sec. 18 T. 11 S. R. 24 E. 24th County  
 PERMIT NO. 12156 10-431-13 well # 3 application map  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE Propagatum  
 Domestic FISH  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pre Forate 7 7/8		0'	41'	
Washed out Sand		75'	88'	
Pumped 20 Bags Abantomite		88'	41'	
Pumped 30 Bags Neat Cement		41'	Surface	
Over night SPITLED Back To 26'				
Pumped Neat Cement approx 9 cubic feet		Surface	From 26'	

8. WELL CONSTRUCTION  
 Depth Drilled 88 Feet Depth Cased 41 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 7 7/8 Inches To 0 Feet 88 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>7 7/8</u>	<u>12</u>	<u>5/16</u>	<u>+6</u>	<u>40'6"</u>

Perforations:  
 Type perforation Half Pre Forater  
 Size perforation 1/4" x 1" x 4 Rows 5 Slot per FT.  
 From 7'6" feet to 40'6" feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 88  Neat Cement To 40'6"  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No 12.1% Bentonite  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet 40'6" TO 88'

9. WATER LEVEL  
 Static water level Start 3' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Old well Fair

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Drilling / PBA Contractor  
 Address 152 N. Bybee Ln Contractor  
Yerington NV 89440  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Ly Ogden Jr  
 By driller performing actual drilling on site or contractor  
 Date 8-14-00

Date started 7-24 2000  
 Date completed 7-26 2000

7. OLD WELL DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Static 3'</u>		
<u>Open Hole 25'</u>		