WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81040
Permit No.
Basin 107

NOTICE OF INTENT NO. 27329

1. OWNER Kim Stewart
MAILING ADDRESS P.O. Box 234
Smith NV 89430

ADDRESS AT WELL LOCATION 161 Day Lane
Smith NV 89430 Log #307
well #26 State engineer map

2. LOCATION NE ¼ NE ¼ Sec. 18 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. 12156 Issued by Water Resources
10-431-13 Parcel No.
well #4 application map Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Propagation
☒ Domestic Fish ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pre Forate 7 7/8		From 0	To 34'	
washed out Sand		84'	To 88'	
Pumped 16 Bags Abantonite From 88' To 34'				
Pumped Neat Cement 34' To Surface approx 12 Cubic FT.				
After 1 HR Settled To 10' Pumped Neat Cement 10' To Surface approx 4 Cubic FT				
After 1 HR Settled To 1' Poured To Surface.				

Date started 7-26 20 00
Date completed 7-27 20 00

7. OLD WELL ~~[illegible]~~ DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Static	4'		
Open Hole	84'		

8. WELL CONSTRUCTION
Depth Drilled 88 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7¼ Inches		0 Feet	88 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7 7/8	12	5/16	+1	87

Perforations:
Type perforation Holt Pre Forater
Size perforation ¼" x 1" x 4 Rows 5 Shots per FT
From 7 ft" feet to 32' 6" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 88
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☒ No
From — feet to — feet

Seal Type:
☒ Neat Cement To 34'
☐ Cement Grout
☐ Concrete Grout
12.1% Bentonite 34' TO 88'

9. WATER LEVEL
Static water level Start 4' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality Old well Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Drilling / DBA Contractor
Address 152 N. Bybee Lane Contractor
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-14-00

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627