WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81041
Permit No.
Basin 107

NOTICE OF INTENT NO. 27330

1. OWNER Kim Stewart
MAILING ADDRESS P.O. Box 234 Smith NV 89430
ADDRESS AT WELL LOCATION 161 Day Lane Smith NV 89430 (No old Log) well #28 State engineer map

2. LOCATION NE ¼ NE ¼ Sec. 18 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. 12156 (Issued by Water Resources) 10-431-13 (Parcel No.) well #5 application map (Note existing 1-2-1948) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Propagation
☒ Domestic + Fish ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other UNKNOW

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pre Forate 7 7/8 From 0' To 41'				
washed out Sand 75' To 78' Loose				
Drilled 78' To 90' 6 1/4" Hole To Find Bottom of Well				
Coarse Sand		78	80	2
Brown clay + Sand		80	90	10
Pumped 9 Bags Abantonite 90' To 41'				
Pump 1/2 yard Neat Cement 41' To Surface				
Settled over Night To 30' Pumped 10 Bag Neat Cement 30' To Surface After 1 HR Settled Settled 2' Poured Neat Cement To Surface				

Date started 7-27 2000
Date completed 8-9- 2000

7. 010 WELL ~~TEST~~ DATA
TEST METHOD: ☐ Bailer ☐ Pump ~~☐ Air Lift~~

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Static	6'		
Open Hole 75'			

8. WELL CONSTRUCTION
Depth Drilled UNKNOW Feet Depth Cased 41 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Unknow Inches	0 Feet	78 Feet approx
6 1/4 Inches	78 Feet	90 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7 7/8	12	5/16	+1	40'

Perforations:
Type perforation Holt Pre Forater
Size perforation 1/4" x 1" x 4 Rows 5 Slots per FT.
From +1 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 90
Placement Method: ☐ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☒ No
From — feet to — feet

Seal Type:
☒ Neat Cement To 40'
☐ Cement Grout
☐ Concrete Grout
12.5% Bentonite 40' To 90'

9. WATER LEVEL
Static water level 6' Start feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality Poor / Thin Pipe

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Drilling / DBA (Contractor)
Address 152 N Bybee Ln (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board:
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-14-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627