

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 81044
 Permit No. _____
 Basin 105

NOTICE OF INTENT NO. 41997

1. OWNER Larry Madsen ADDRESS AT WELL LOCATION 1348 View Pl
 MAILING ADDRESS 1611 Meadow Ln Gardnerville NV 89410
Los Alamos NM, 87544
 2. LOCATION S1/4 NE 1/4 Sec 2 T. 12 N. R. 20 E Douglas County
 PERMIT NO. 23-100-100 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Hard Pan Clay</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Cobbles and Gravels</u>		<u>3</u>	<u>63</u>	
<u>Small obisidian Sands</u>		<u>63</u>	<u>147</u>	
<u>Brown Gummy Clay</u>		<u>147</u>	<u>208</u>	<u>61</u>
<u>Small coarse sands</u>		<u>208</u>	<u>213</u>	<u>5</u>
<u>Brown Clay</u>		<u>213</u>	<u>217</u>	<u>4</u>
<u>Fractures and 1/4 Gravels</u>	<u>XX</u>	<u>217</u>	<u>240</u>	<u>23</u>

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 246 Feet
10 3/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 0 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 240 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat Dr. Contractor
Carson City NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Heck
 By driller performing actual drilling on site or contractor
 Date 8/12/00

Date started 8-9, 1900
 Date completed 8-10, 1900

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>35</u>	<u>2 HRS</u>