

Log No. 81045
 Permit No. 105
 Basin.....

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41794

1. OWNER DE Jansse & Co Inc ADDRESS AT WELL LOCATION 1345 View Pt. Gardnerville NV 89410
 MAILING ADDRESS 1589 SADDY A Cr. Minden NV 89423
 2. LOCATION NW 1/4 NW 1/4 Sec. 2 T 12 S R 20 E Douglas County
 PERMIT NO. 23-610-120 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Hard Pan Clay</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Cobbles and Loose Sands & Gravels</u>		<u>2</u>	<u>75</u>	<u>72</u>
<u>Brown Sandy Clay w/ Gravel Strata</u>		<u>75</u>	<u>160</u>	<u>85</u>
<u>Brown Clay</u>		<u>160</u>	<u>170</u>	<u>10</u>
<u>Fractured Lamination Cobbles and obsidian Sands</u>		<u>170</u>	<u>225</u>	<u>52</u>

8. WELL CONSTRUCTION
 Depth Drilled 225 Feet Depth Cased 225 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 225 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/4</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>225</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 225 feet to 225 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100' feet to 225 feet

RECEIVED
 00 JUN 19 AM 11:24
 STATE ENGINEERS OFFICE

Date started 6-6, 1960
 Date completed 6-8, 1960

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>45</u>	<u>3 HRS</u>

9. WATER LEVEL
 Static water level 9.5 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat Dr. Contractor
CARSON CITY NV 89704
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Hook
 By driller performing actual drilling on site or contractor
 Date 6-10-60