

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 81049  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41947

1. OWNER DE JASSE, Co Inc ADDRESS AT WELL LOCATION: 818 Bucksie's Ln  
 MAILING ADDRESS: 1589 Saratoga Cir Gardnerville NV 89410  
Mindas NV 89423

2. LOCATION NE 1/4 NE 1/4 Sec 24 T 12 S R 20 E Douglas County  
 PERMIT NO. 12-218-401 / 1221-18-401-004  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Hard Pan Clay</u>		<u>0</u>	<u>36</u>	<u>36</u>
<u>Coarse DG Sands and Clay Strata</u>		<u>36</u>	<u>136</u>	<u>100</u>
<u>Brown Sandy Clay</u>				
<u>Brown Wet Crumbly Clay</u>		<u>136</u>	<u>145</u>	<u>9</u>
<u>Brown Clay</u>		<u>145</u>	<u>180</u>	<u>35</u>
<u>Fractured Volcanic Sands and Small Ruddy Gravels</u>	<u>XX</u>	<u>180</u>	<u>220</u>	<u>40</u>

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/4 Inches 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3 x 3/32  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 22 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Capital City Well Drilling Contractor  
 Address 20 Kit Kat Dr. Contractor  
Carson City NV 89706

Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date 7-5-00

Date started 6-28, 1900  
 Date completed 7-1, 1900

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>22</u>	<u>40</u>	<u>3 HRS</u>

RECEIVED  
 00 JUL 19 AM 8:39  
 STATE ENGINEERS OFFICE