

MW-1

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

File No. 81059

Permit No.

Basin. 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44102

1. OWNER Park Cattle Company Inc.

MAILING ADDRESS 1300 Dunkeye Rd
Minden, NV 89423

ADDRESS AT WELL LOCATION Mueller Lane
Douglas Co.

2. LOCATION SE 1/4 SE 1/4 Sec. 23 T. 13

N 19 E DOUGLAS County

PERMIT NO. N/A 17-190-39

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED

- New Well
- Replace
- Recondition
- Deepen
- Abandon
- Other.....

4. PROPOSED USE

- Domestic
- Municipal/Industrial
- Irrigation
- Monitor
- Test
- Stock

5. WELL TYPE

- Cable
- Rotary
- RVC
- Air
- Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Black Silty Clay (CH) MED. STIFF MOIST. (ORGANIC)		0.0	1.0	1.0
BLACK CLAY (CH) STIFF, VERY MOIST		1.0	14.0	13.0
WATER LEVEL (STATIC)	4.0			
WATER LEVEL 1 ST ENCOUNTERED	11.0			
BLACK SILTY SAND (SM) LOOSE, SATURATED		14.0	21.0	7.0

8. WELL CONSTRUCTION

Depth Drilled 21.0 Feet Depth Cased 19.0 Feet

HOLE DIAMETER (BIT SIZE)

From 7 3/4 Inches 0.0 Feet 21.0 Feet
 To 21.0 Feet
 Inches. Feet
 Inches. Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.70	0.308	0.0	4.0

Perforations:

Type perforation SLOTTED

Size perforation 0.020

From 4.0 feet to 19.0 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal:

Yes No

Seal Type:

Depth of Seal 1.0 - 0.0
 Placement Method: Pumped (bentonite) Cement Grout
 Poured (1.0 - 3.0) Concrete Grout

Sand #8

Gravel Packed: Yes No

From 3.0 feet to 21.0 feet

9. WATER LEVEL

Static water level 4.0 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature 62 °F Quality Silty, cloudy

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DALE LEHMAN w/ PEZONELLA ASSOC.
Contractor

Address 520 EDISON WAY
Contractor

RENO, NV 89502

Nevada contractor's license number issued by the State Contractor's Board N/A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976

Signed Dale Lehman
By driller performing actual drilling on site or contractor

Date 5/31/00

Date started MAY 30, 2000

Date completed MAY 30, 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)