WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81069
Permit No. 94
Basin

NOTICE OF INTENT NO. 45025

1. OWNER RICHARD NOLAN
MAILING ADDRESS P.O. BOX 14212
Reno, Nevada 89507

ADDRESS AT WELL LOCATION 15085 Gooding Drive
Reno, Nevada 89506

2. LOCATION NE SE ¼ NE SW ¼ Sec. 57 T. 22N N/S R. 19 E. Washoe County

PERMIT NO. (Issued by Water Resources) 079-382-42 (Parcel No.) Red Rock Estates #8C Parcel 4 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	7	6
Brown sandy clay		7	16	9
Cemented sands		16	23	7
Brown sandy clay		23	45	22
Cemented sands		45	51	6
Brown sandy clay		51	87	36
Gray sandy clay		87	90	3
Soft zone	X	90	94	4
Gray sandy clay		94	111	17
Soft zone	X	111	121	10
Gray sandy clay		121	142	21
Soft zone	X	142	161	19
Gray sandy clay		161	165	4

Date started July 27, 2000, ~~19XX~~
Date completed July 28, 2000, ~~19XX~~

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+		

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	165 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	165

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 100 feet to 120 feet
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. 40+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board: 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: ~~12626~~ 923

Signed (By driller performing actual drilling on site or contractor)
Date August 10, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627