

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44590

1. OWNER Schneeberger
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION SW cor Hootent Deodar Silver Springs
 2. LOCATION NW SE SW NE SE 13 T 17 N/S R 24 E Lyon County
 PERMIT NO. 17-253-08
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Med

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|------------------------|--------------|------------|------------|-----------|
| <u>Sand</u> | | <u>0</u> | <u>86</u> | |
| <u>Tanday</u> | | <u>86</u> | <u>142</u> | |
| <u>Sand and gravel</u> | | <u>142</u> | <u>176</u> | |
| <u>loamy clay</u> | | <u>176</u> | <u>181</u> | |
| <u>loam sand</u> | | <u>181</u> | <u>200</u> | |

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>13.00</u> | <u>5/16</u> | <u>71</u> | <u>20</u> |
| <u>6 5/8</u> | <u>3.00</u> | <u>3/4</u> | <u>20</u> | <u>200</u> |

Perforations:
 Type perforation split saw
 Size perforation 1 1/4 x 6
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 0-50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 90 feet to 200 feet

RECEIVED
 00 SEP -6 AM 9:55
 STATE ENGINEERS OFFICE

Date started 6-15 2000
 Date completed 6-17 2000

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Stat) | Time (Hours) |
|--|------------------------------|-----------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>produced about 40 GPM</u> | | |

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Recep Phillips Inc Contractor
 Address PO Box 599 Contractor
Silver Springs NV 89979
 Nevada contractor's license number issued by the State Contractor's Board: CO 31891
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 141877
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-17-00