

Log No. 81076  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43072

1. OWNER Charles Grant Toast ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Box 2175 \_\_\_\_\_  
Minden, N.V. \_\_\_\_\_  
 2. LOCATION NW 1/4 SE 1/4 Sec 3 T 13 N S R 20 E Douglas County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand &amp; Gravel</u>		<u>0</u>	<u>68</u>	<u>68</u>
<u>Sandy Clay</u>		<u>68</u>	<u>223</u>	<u>55</u>
<u>Sand &amp; Gravel</u>		<u>223</u>	<u>230</u>	<u>7</u>
<u>Sandy Clay</u>		<u>230</u>	<u>236</u>	<u>6</u>
<u>SAND &amp; GRAVEL</u>	<input checked="" type="checkbox"/>	<u>236</u>	<u>265</u>	<u>29</u>

8. WELL CONSTRUCTION  
 Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 265  
10 5/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.088</u>	<u>+2</u>	<u>265</u>

Perforations:  
 Type perforation Factory Milled  
 Size perforation 10 x 3 1/8  
 From 245 feet to 265 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 265 feet

9. WATER LEVEL  
 Static water level 12.3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eddco Exploration Inc Contractor  
 Address 7780 Curry Rd Contractor  
Fallon, NV  
 Nevada contractor's license number issued by the State Contractor's Board 27673 A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6-1-00

Date started 5-21-00, 19\_\_\_\_  
 Date completed 5-31-00, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25</u>		<u>1 1/2 hrs</u>