WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
SDW-6
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81080
Permit No.
Basin

NOTICE OF INTENT NO. 44757

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480'
Round Mountain Nevada 89045

ADDRESS AT WELL LOCATION Round Mountain Gold Corporation Pit

2. LOCATION SE ¼ NE ¼ Sec 30 T 10 S R 44 E Nye County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tuff		0	300'	300'
Cement		0	10'	10'
⅜ Holy Plug		10	100'	90'
Sand Pack		100'	295'8"	195'8"
Bottom Plug		295'8		

Date started 6-5 2000
Date completed 6-6 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	1		5min.
200	10		5min.
300	20		5min

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 295'8" Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14"	Inches	0 Feet	10 Feet
8.750	Inches	10 Feet	300 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 5/8"		3/16 wall	0	10
4"		SCH 40	+1	295'8"

Perforations:
Type perforation Horz. Slot
Size perforation 0.020
From 138'6" feet to 295'8" feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100' feet to 295'8" feet

9. WATER LEVEL
Static water level 95' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co. (Contractor)
Address P.O. Box 2748 (Contractor)
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1786
Signed Craig Dines
By driller performing actual drilling on site or contractor
Date 6-6-2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627