WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81095
Permit No.
Basin 105

NOTICE OF INTENT NO. 42000

1. OWNER Frank Forselius
MAILING ADDRESS 1608 Finch DR. San Francisco CA
ADDRESS AT WELL LOCATION 1608 Finch DR Gardnerville NV 89410

2. LOCATION SW ¼ SW ¼ Sec. 29 T. 13 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-150-280 (Parcel No.) Fish Springs Area (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Over Burden Hard Pan Clay		0	4	4
Cobbles and Cemented Gravels		4	18	14
Course Gravels Red Obsidian Sands		18	76	58
Clay Stringers Small Sands		78	110	34
Brown Gummy Clay		110	193	83
Course Fractured Gravels W/Small Clay Seams	XX	193	240	47

Date started 8-7, 1900
Date completed 8-9, 1900

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
33	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	240 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	240

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow NO G.P.M. 33 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kitty DR. Carson City NV 89706 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-10-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627