WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81105
Permit No.
Basin 105

NOTICE OF INTENT NO. 41948

1. OWNER Carl Hayward
MAILING ADDRESS 1515 Patrick Ct.
Decarlo Custom Homes Po Box 2844 Minden

ADDRESS AT WELL LOCATION 1515 Patrick Ct
Gardnerville NV 89410

2. LOCATION NW ¼ NW ¼ Sec. 32 T. 13 N/S R. 21 E. Douglas County
PERMIT NO. Issued by Water Resources | 23-170-18 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Pan		0	2	2
Cobbles and Cemented Gravels		2	18	16
Brown Clay		18	36	18
Course Brown Sands and Clay Zones		36	163	127
Brown Gummy Clay		163	210	47
Gray Clay		210	231	21
Brown Sandy Clay		231	315	84
Fractured Zone Sands and Gravels Course Dk Sands	XX	315	360	45

Date started 6-12, 1900
Date completed 6-15, 1900

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	45	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	360 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	360

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 340 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 195 feet below land surface
Artesian flow G.P.M. 30+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat DR Contractor
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 6-15-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627