

OFFICE USE ONLY  
 Log No. 81106  
 Permit No. \_\_\_\_\_  
 Basin 108

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44598

1. OWNER Bunito + Felicitas Montes ADDRESS AT WELL LOCATION 20 Thurston Way  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 SE 1/4 Sec. 9 T 13 N/S R 25 E Lyon County \_\_\_\_\_  
 PERMIT NO. 14-592-07 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Misc

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Clay		1	23	
Clay		23	46	
Sand Gravel		46	74	
Gravel		74	87	
Clay		87	94	
Gravel, Sand		94	124	
Clay	130	124	130	
Gravel	130	130	130	

8. WELL CONSTRUCTION  
 Depth Drilled 130 Feet Depth Cased 130 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 1/8 Inches To 130 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>20</u>
<u>6 5/8 PIP 40</u>			<u>20</u>	<u>130</u>

Perforations:  
 Type perforation Machine Pump  
 Size perforation 3.11 x 4 x 5 grout  
 From 160 feet to 178 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 120 feet to 130 feet

9. WATER LEVEL  
 Static water level 28 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 2 °F Quality Good

Date started 3/13/00, 19\_\_\_\_  
 Date completed 5/16/00, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>1 3/4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jason D. ... Contractor  
 Address PO Box 35 NV 89405 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0001841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 6/12/00