WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81107
Permit No.
Basin 108

NOTICE OF INTENT NO. 42886

1. OWNER Yerington Public Utilities
MAILING ADDRESS 102 South Main St.
Yerington, NV 89447

ADDRESS AT WELL LOCATION Corner of South First St. and 4th St. in Mason, NV.

2. LOCATION SE 1/4 NW 1/4 Sec. 33 T 13N N/S R 25E E Lyon County
PERMIT NO. ~~18671~~ 18571 (Issued by Water Resources) | Parcel No. | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mobilized to the site and removed 126' of 4" drop pipe and submersible pump. Measured static water level at 88.43'. Total depth of well measured was 143'. Bailed debris from well to a depth of 147'. We could not advance any further due to the bailer becoming lodged in the bottom of the well. We then installed our 12" Mills Knife and perforated 5 rows per foot from 90' to 50'. After perforating was completed, we installed 147' of 2" tremme pipe for the neat cement. The following morning, we pumped in approximately 8 cubic yards of neat cement. Casing volume should have only required 4.5 cubic yards.				

Plugging of log # 5109

Date started 7/5/00, 19__
Date completed 7/7/00, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 147 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12		.250	+1	147'

Perforations:
Type perforation Mills Knife
Size perforation
From 90 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 147
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 88.43 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 7/10/00

USE ADDITIONAL SHEETS IF NECESSARY