

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 81110
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43350

1. OWNER LAS VEGAS PAVING/SUNRIDGE ADDRESS AT WELL LOCATION SUNRIDGE GOLF COURSE C INDIAN HILL
 MAILING ADDRESS 4420 SO. DECATUR LAS VEGAS, NV 89103

2. LOCATION SE 1/4 NE 1/4 Sec 8 T 14 S R 20 E DOUGLAS County
 PERMIT NO. 65965T Parcel No. 21 280 42 Subdivision Name SUNRIDGE GOLF COURSE

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>CONK FILL</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>GREY DG</u>		<u>8</u>	<u>60</u>	
<u>SANDY GREY CLAY</u>		<u>60</u>	<u>80</u>	
<u>GREY CLAY, MIXED DG</u>	<u>X</u>	<u>80</u>	<u>130</u>	
<u>CLS, SAND, SML GRVL</u>	<u>X</u>	<u>130</u>	<u>200</u>	
<u>GRVLY GREY CLAY</u>		<u>200</u>	<u>219</u>	
<u>GRVLS TO 2" W</u>	<u>X</u>	<u>219</u>	<u>243</u>	
<u>SAND</u>				
<u>SANDY GREY CLAY</u>		<u>243</u>	<u>263</u>	
<u>LARGER GRVLS W</u>	<u>X</u>	<u>263</u>	<u>279</u>	
<u>SAND</u>				
<u>SANDY GREY CLAY</u>		<u>279</u>	<u>300</u>	

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches To 300 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>.188</u>	<u>+2</u>	<u>300</u>

Perforations:
 Type perforation FACTORY SAWCUT
 Size perforation 3 X 7/32
 From 140 feet to 180 feet
 From 220 feet to 240 feet
 From 260 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 300 feet

9. WATER LEVEL
 Static water level GL feet below land surface
 Artesian flow 20+ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality _____

Date started MAY 10 1900
 Date completed MAY 16 1900

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>4-600</u>	<u>✓</u>		<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CRK RD
CARSON CITY, NV 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1720
 Signed Joe Deisek
 By driller performing actual drilling on site or contractor
 Date MAY 23 / 00