

OFFICE USE ONLY
 Log No. 81112
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 41951

1. OWNER Blain McGuire Construction Inc ADDRESS AT WELL LOCATION 1582 Gloria
 MAILING ADDRESS 2110 Lakeshore DR. Minden NV. 89423
Carson City NV. 89204

2. LOCATION NE 1/4 NE 1/4 Sec 27 T 14 N R 20 E Douglas County
 PERMIT NO. 21-140-69 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|--|--------------|--------|--------|-----------|
| Hard Pan Sands | | 0 | 6 | 6 |
| Very Soft Sands Blow Sands | | 6 | 17 | 11 |
| Course DG Sand | | 17 | 17 1/2 | 15 9/16 |
| Brown Silty Sand (Soft) | | 17 1/2 | 23 7/8 | 6 1/8 |
| Brown Clay Stratas DG Silty Sands Very Soft | | 23 7/8 | 31 0 | 7 3/8 |
| Hard Fractured DG Sands and Obsidian Gravels | XX | 31 0 | 34 0 | 3 0 |

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 340 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>13.03</u> | <u>.188</u> | <u>0</u> | <u>340</u> |

Perforations:
 Type perforation M.I. slot
 Size perforation 3x 3/32
 From 300 feet to 340 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 340 feet

RECEIVED
 00 JUL 19 AM 8:39
 WATER RESOURCES DIVISION

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature Cold °F Quality Good

Date started 7-8, 1900
 Date completed 7-10, 1900

7. WELL TEST DATA

| TEST METHOD: | | | |
|--------------|-------------------------------|--------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| <u>25</u> | <u>35</u> | <u>3 HR</u> | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat DR. Contractor
Carson City NV 89206
 Nevada contractor's license number issued by the State Contractor's Board 41725
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Heck
 By driller performing actual drilling on site or contractor
 Date 7-11-00