

Log No. 8113
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 4409B

1. OWNER J & D CONSTRUCTION ADDRESS AT WELL LOCATION 1019 Nobles Court
 MAILING ADDRESS Minden NV Minden, NV.
 2. LOCATION S.W. 1/4, S.E. 1/4 Sec 32 T 14 N S R. 20 E Douglas County
 PERMIT NO. 1420-32-002-003 22-02-94 Johnson Lane Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Med

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay Soil</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>FINE DG</u>		<u>6</u>	<u>31</u>	<u>25</u>
<u>DARK CLAY</u>		<u>31</u>	<u>43</u>	<u>12</u>
<u>COURSE SAND</u>	<input checked="" type="checkbox"/>	<u>43</u>	<u>107</u>	<u>64</u>
<u>DARK CLAY</u>		<u>107</u>	<u>122</u>	<u>15</u>
<u>COURSE SAND & Clay Seams</u>	<input checked="" type="checkbox"/>	<u>122</u>	<u>150</u>	<u>28</u>

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.108</u>	<u>7</u>	<u>150</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 1/2 x 3/4
 From 130 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 150 feet

9. WATER LEVEL
 Static water level 12' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 7-10 00
 Date completed 7-12 00

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air</u>	<u>+25</u>		<u>1hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Exploration Inc Contractor
 Address 7780 CURRY RD Contractor
FALLEN, NV 89406
 Nevada contractor's license number 27673A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1526
 Signed [Signature]
 By [Signature] performing actual drilling on site or contractor
 Date 7-17-00