

OFFICE USE ONLY
 Log No. 81133
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43213

1. OWNER Ray & Christina Sawyer ADDRESS AT WELL LOCATION Lot 7 - 4th East
 MAILING ADDRESS P.O. Box 878 Cross Timbers
Mc. Gill N.V. 89318

2. LOCATION S.W. 1/4 N.W. 1/4 Sec. 14 T. 17 N/S R. 63 E White Pine County
 PERMIT NO. N/A 5-581-65 Parcel No. Cross Timbers Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>2</u>	
<u>Sand gravel clay cobble</u>		<u>2</u>	<u>38</u>	
<u>Clay</u>		<u>38</u>	<u>41</u>	
<u>Clay gravel conglomerate</u>		<u>41</u>	<u>47</u>	
<u>gravel con.</u>		<u>47</u>	<u>63</u>	
<u>Clay con</u>		<u>63</u>	<u>69</u>	
<u>gravel sand</u>	<u>water</u>	<u>69</u>	<u>73</u>	
<u>Clay</u>		<u>73</u>	<u>75</u>	
<u>gravel</u>	<u>water</u>	<u>75</u>	<u>104</u>	
<u>Clay con.</u>		<u>104</u>	<u>120</u>	
<u>gravel</u>	<u>water</u>	<u>120</u>	<u>135</u>	
<u>Clay con</u>		<u>135</u>	<u>140</u>	

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>50</u>		
<u>8</u>	<u>50</u>	<u>80</u>		
<u>6</u>	<u>80</u>	<u>140</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>-1</u>	<u>140</u>

Perforations:
 Type perforation MILL
 Size perforation 8 x 2.5" x 6 row

From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 80 feet to 100 feet
 From 120 feet to 140 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 80 feet

9. WATER LEVEL
 Static water level 63 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 64.4 °F Quality good

Date started June 30 2000
 Date completed July 22 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>1</u>	<u>1 hr.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Orvan K. Maynard Contractor
 Address P.O. Box 64 Lund N.V. 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047226
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Orvan Maynard
 By driller performing actual drilling on site or contractor
 Date July 24-00