

OFFICE USE ONLY  
 Log No. 81136  
 Permit No. 87  
 Basin SW Reno

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43870

1. OWNER WILLIAM CURTIS ADDRESS AT WELL LOCATION 2465 Kinney Lane  
 MAILING ADDRESS 1365 Dartmouth Drive Reno, Nevada 89511  
 2. LOCATION SW 1/4 NE 1/4 Sec 2 T 18N N/S R 19 E Washoe County  
 PERMIT NO. 222-072-05 SW Reno  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	1	1
Brown clay w/gravels		1	3	2
Brown weathered volcanic rock		3	18	15
Brown volcanic rock		18	36	18
Soft zone (NO WATER)		36	37	1
Brown volcanic rock		37	58	21
Soft zone	X	58	61	3
Brown volcanic rock		61	72	11
Purple volcanic rock		72	90	12
Volcanic fracture rock		90	103	13
Gray volcanic rock		103	106	3
Broken fracture rock	X	106	118	12
Gray volcanic rock		118	127	9

8. WELL CONSTRUCTION  
 Depth Drilled 127 Feet Depth Cased 127 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 100 Feet  
8 5/8 Inches 100 Feet 127 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	127

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 103 feet to 123 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100 foot  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 127 feet

9. WATER LEVEL  
 Static water level 49 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 60+ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 0022549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923  
 Signed [Signature]  
 driller performing actual drilling on site or contractor  
 Date July 12, 2000

Date started July 5, 2000   
 Date completed July 11, 2000

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>60+</u>			