Beylik Job #: 41166 Owner's Well #: MW-237

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81153
Permit No.
Basin 87

NOTICE OF INTENT NO. 13628

1. OWNER Vista Canyon Group
MAILING ADDRESS 1100 Town & Country Rd.
Orange, CA 92868

ADDRESS AT WELL LOCATION
Sparks Marina Park Lake
South Side

2. LOCATION SW ¼ NW ¼ Sec. 10 T 19 N S R 20 E Washoe County

PERMIT NO. (Issued by Water Resources) | Parcel No. 37-030-25 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown silty sand		-0-	9	9
Fine dk. borwn gravel		9	11	2
Fine to coarse gravel		11	14	3
Fine to coarse sand		14	15	1
Fine to coarse sand, coarse gravel, cobbles, boalders		15	33	18

Date started May 11, 2000
Date completed May 12, 2000

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 29.5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14-3/4	Inches	-0-	Feet	5	Feet
9-7/8	Inches	5	Feet	33	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	Sch40	-0-	9.5
4.5	PVC	Sch40	9.5	29.5

Perforations:
Type perforation Mill Slot
Size perforation 0.50
From 9.5 feet to 29.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Pellets
Gravel Packed: ☒ Yes ☐ No
From 7 feet to 29.5 feet

9. WATER LEVEL
Static water level 12.1 feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Donald Stratton for Beylik Drilling (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631-6124

Nevada contractor's license number issued by the State Contractor's Board 0007055A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011

Signed (By driller performing actual drilling on site or contractor)

Date June 29, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627