

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43883

1. OWNER GARY BRAZZANOVICH ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 17410 Northridge Avenue  
Reno, Nevada 89506

2. LOCATION SW 1/4 SE 1/4 Sec. 29 T. 21N N/S R. 18 E. Washoe County  
 PERMIT NO. 081-181-19 Coldsprings Subdivision Name  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material                    | Water Strata | From | To  | Thick-ness |
|-----------------------------|--------------|------|-----|------------|
| WELL DEEPENING              |              |      |     |            |
| Static water level @47 feet |              |      |     |            |
| Fill gray sand & clay       |              | 140  | 150 | 10         |
| Gray sandy clay             |              | 150  | 153 | 3          |
| Soft zone (NO WATER)        |              | 153  | 156 | 3          |
| Gray sandy clay             |              | 156  | 178 | 22         |
| Soft zone (NO WATER)        |              | 178  | 181 | 3          |
| Gray sandy clay             |              | 181  | 203 | 22         |
| Soft zone (NO WATER)        |              | 203  | 206 | 3          |
| Gray sandy clay             |              | 206  | 213 | 7          |
| Soft zone (NO WATER)        |              | 213  | 215 | 2          |
| Gray sandy clay             |              | 215  | 218 | 3          |
| Soft zone (app 2 GPM)       | X            | 218  | 219 | 1          |
| Gray sandy clay             |              | 219  | 235 | 16         |
| Hard streak                 |              | 235  | 240 | 5          |
| Light gray sandy clay       |              | 240  | 255 | 15         |
| Gray sandy clay             |              | 255  | 268 | 13         |
| Hard streak                 |              | 268  | 271 | 3          |
| Gray sandy clay             |              | 271  | 300 | 29         |

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
8 Inches 140 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              |                     | .188                    | 0           | 300       |

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around

From 140 feet to 180 feet  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal deepening Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 140 feet to 300 feet

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 5 P.S.I.  
 Water temperature cold °F Quality clear

Date started August 15, 2000 XX  
 Date completed August 17, 2000 XX

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.   | Draw Down (Feet Below Static) | Time (Hours) |
|----------|-------------------------------|--------------|
| <u>5</u> |                               |              |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the 923  
 Division of Water Resources; the on-site driller \_\_\_\_\_

Signed [Signature]  
 driller performing actual drilling on site or contractor  
 Date August 18, 2000