WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81170
Permit No.
Basin 162

NOTICE OF INTENT NO. 19097

1. OWNER Elton Reinhardt
MAILING ADDRESS 3360 W. Palm Lane, Pahrump, Nevada 89048
ADDRESS AT WELL LOCATION 3360 W Palm Lane, Pahrump, Nevada 89048

2. LOCATION NW ¼ SE ¼ Sec. 24 T. 19 N/S R. 52 E. Nye County
PERMIT NO. Issued by Water Resources; Parcel No. 27-732-74; Subdivision Name Nye County

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	10'	10'
caliche		10'	15'	5'
white clay		15'	35'	20'
caliche		35'	40'	5'
white clay		40'	60'	20'
caliche		60'	70'	10'
white clay		70'	100'	30'
caliche		100'	105'	5'
white clay		105'	110'	5'
brown clay		110'	125'	15'
caliche		125'	130'	5'
brown clay		130'	140'	10'

SEP 11 2000

Date started August 9, 2000
Date completed Aug. 14, 2000

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0'	140'

Perforations:
Type perforation Saw cut
Size perforation 1/8" X 3"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to feet

9. WATER LEVEL
Static water level 55' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Co. (Contractor)
Address 4191 S. Jackie St. (Contractor)
Pahrump, Nevada 89048
Nevada contractor's license number issued by the State Contractor's Board 049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue
By driller performing actual drilling on site or contractor
Date 8/28/2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627