WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81174
Permit No.
Basin 212

NOTICE OF INTENT NO. 37344

1. OWNER Nellis AFB 99ABW/EMC
MAILING ADDRESS 4349 Duffer Dr. Suite 1601
Nellis AFB NV 89191-7007

ADDRESS AT WELL LOCATION
Facility No.: 60937

2. LOCATION NW ¼ SW ¼ Sec 10 T 20 N/S R 62 E Clark County
PERMIT NO. (Issued by Water Resources) ~~NA~~ 140-10-301-004 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand (Fill)		0	10.5	10.5
Clayey Silt(Alluvium)		10.5	44.0	33.5
Silty Clay		44.0	80.5	36.5

Date started July 12, 2000, 19
Date completed July 13, 2000, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	80.5 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.05	0.237	0	80.5

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 40 feet to 80 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 38'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 38 feet to 80.5 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 68 °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gregg Drilling & Testing, INC. (Contractor)
Address 2726 Walnut Ave. (Contractor)
Signal Hill, CA 90806
Nevada contractor's license number issued by the State Contractor's Board 0038113
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2018
Signed ____ By driller performing actual drilling on site or contractor
Date 9-1-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627