WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81176
Permit No.
Basin 230

NOTICE OF INTENT NO. 44803

1. OWNER Edward Boass
MAILING ADDRESS 2021 E. Nevada Blvd #19
Pahrump NV 89048

ADDRESS AT WELL LOCATION 1999 Miner Rd.
Amargosa Valley NV 89020

2. LOCATION SE ¼ SW ¼ Sec. 7 T. 17 N(S) R. 49 E. Nye County
PERMIT NO. Issued by Water Resources | Parcel No. 19-401-30 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	55	55
Caliche		55	60	5
Sandstone		60	65	5
Limestone	1st	65	95	30
Clay		95	114	19
Limestone		114	118	4
Clay		118	122	4
Sand & gravel	2nd	122	137	15
Limestone		137	145	8
Sand & gravel		145	175	30
fractured limestone w/sand		175	200	25
Bottom of Hole			200	

SEP 2 2000

Date started Aug 23 2000, 19
Date completed Aug 25 2000, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8" PVC Surface Protective Casing				
16 X 10" Steel		.1808 Wall		

Perforations:
Type perforation Machined
Size perforation 3"x1/8" every 12"
From 80 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address HCR 69 Box 452 Contractor
Amargosa Valley, NV 89020
Nevada contractor's license number issued by the State Contractor's Board 53764A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed
By driller performing actual drilling on site of contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627