WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81178
Permit No.
Basin 230

NOTICE OF INTENT NO. 44802

1. OWNER Ron Moore
MAILING ADDRESS P.O. Box 512
Amargosa Valley, NV 89020
ADDRESS AT WELL LOCATION E. Farm Rd
Amargosa Valley NV 89020

2. LOCATION NW ¼ SW ¼ Sec. 7 T. 17 N/S R. 50 E. Nye County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Clay + gravel		10	50	40
Caliche		50	55	5
Sand + clay		55	80	25
Clay		80	105	25
Clays		105	115	10
Sand + gravel	1st	115	120	5
Clay		120	190	70
Sand rock + gravel		190	195	5
Clay + sand		195	205	10
Sand + gravel	2nd	205	215	10
Limestone		215	240	25

Date started 8-7-00, 19
Date completed 8-10-00, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	240 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" PVC Surface Protective Casing 6' of 10" Steel .1808 Wall				

Perforations:
Type perforation Machined
Size perforation 3" x 1/8" every 12"
From 80 feet to 120 feet
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address HCR 69 Box 450 Contractor
Amargosa Valley NV 89020
Nevada contractor's license number issued by the State Contractor's Board 5376 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627